

Test sponsor	Certificate issue date	Certificate number
Composite Specialties Pty Ltd 126 O'Connell Street North Parramatta, NSW, 2151, Australia	30 August 2019	SFCRTF180282.2

Description of the test specimen

The sponsor described the material as Alumate Cladding and Screening – Grade 6063, temper T5 aluminium alloy to be used for external cladding and soffit lining. The material had a measured density of 2712 kg·m⁻³. Please refer to the referenced test report in Table 1 for a complete description of the test specimen, construction and significant behaviour.

Test information

The specimen was tested by Warringtonfire Australia on behalf of the test sponsor in accordance with the test standard identified in Table 1. It achieved the results shown below.

Table 1 Test and report details

Referenced report	Test standard	Test date	Referenced report issue date
RTF180282.2	AS 1530.1:1994 (R2016)	3 December 2018	5 August 2019

Test results

The material, as described in the referenced test report in Table 1, is **NOT DEEMED COMBUSTIBLE** according to the test criteria for combustibility specified in Clause 3.4 of AS 1530.1:1994 (R2016).

Conditions/validity

- This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance.
- Please refer to the relevant test report to determine the applicability of the test result to a proposed installation and for a full description of the tested construction.
- The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.
- All work and services carried out by Warringtonfire Australia are subject to, and conducted in accordance with our standard terms and conditions. These are available on request or at <https://www.element.com/terms/terms-and-conditions>.

Testing authority	Warringtonfire Australia Pty Ltd	
Address	Unit 2, 409-411 Hammond Road, Dandenong South, VIC 3175	
Phone	T: +61 (0)3 9767 1000	
ABN	81 050 241 524	
Email	info.fire.melbourne@warringtonfire.com	
Authorisation	Prepared by:	Reviewed by:
		
	Anthony Rosamilia	Tanmay Bhat